



# AGA CERTIFIED PRODUCT

Certificate Holder: **COPRECI S COOP**  
ABN/ACN No. (if applicable): **N/A**  
Manufacturer: **ALTSASUKO S.COOP**  
Agent (if applicable): **N/A**  
Type of Component: **Type 2 Manual Shut Off Valve**



Model No. & Description: **COPRECI  
CAM23800/219**  
(Refer [www.aga.asn.au](http://www.aga.asn.au) for more details)  
Rated maximum working pressure: 6.5 kPa  
Temperature Range: 0°C to 150°C

Relevant Standard(s): **AS 4617 – 2018**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

**This Certificate is issued on the express conditions that:**

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.



*John Vanderz*

**Client Manager**

*[Signature]*

**Certificate Authorised**

Certificate first issued: **23 April 2019**

Certificate No: **8781**

This copy valid from: **23 April 2019**

Refer specification issue: **01**

QF714/11