



Ref. Certif. No.

CA/35840/CSA

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Automatic Electrical Burner Control
Name and address of the applicant	Copreci S. Coop Ltda. Avda de Alava 3Apartado 62Aretxabaleta, Guipuzcoa 20550 Spain
Name and address of the manufacturer	Copreci S. Coop Ltda. Avda de Alava 3Apartado 62Aretxabaleta, Guipuzcoa 20550 Spain
Name and address of the factory	Copreci S. Coop Ltda. Avda de Alava 3Apartado 62Aretxabaleta, Guipuzcoa 20550 Spain
Note: When more than one factory, please report on page 2	<input type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	5VDC input, 4.5A
Trademark / Brand (if any)	Cp
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	SMV CU
Additional information (if necessary may also be reported on page 2)	Burner Modulated Valve Drive output (6 channels total): 5Vdc, 5A; Main Valve Drive output: 5Vdc, 0.5A <input type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60730-2-5:2013, IEC 60730-2-5:2013/AMD1:2017, IEC 60730-2-5:2013/AMD2:2021 in conjunction with IEC 60730-1:2013, IEC 60730-1:2013/AMD1:2015, IEC 60730-1:2013/AMD2:2020
As shown in the Test Report Ref. No. which forms part of this Certificate	CB 189101-80200834

This CB Test Certificate is issued by the National Certification Body



CSA Group
178 Rexdale Boulevard
Toronto, ON M9W 1R3 Canada

Zekarias Bekele

Date: 2024-12-10

Signature: Zekarias Bekele, P.Eng.